



# Certificate of Compliance

This Certifies that

**160mm SN4 (Class 200) Flexi pipe**

Manufactured by Cromford Pipe  
Conforms to:

Specifications	AS 2439	Test Method	Requirement	Result	
Freedom from defects	2.3	Visual inspection	Clause 2.3.1	√	Pass
Length	2.4.2	Measurement	Clause 2.4.2	√	Pass
Physical Properties	3.1	Appendix B	Slot range 3 > <10 with minimum 1500mm <sup>2</sup> /LM	√	Pass
Stiffness Properties	5.7	AS/NZS 1462.22	>4000 @ 5% Deflection >3400 @ 10% Deflection	√	Pass

## Using test methods specified in:

*AS 2439.1 Perforated Drainage Pipe and Associated Fittings, Part 1 2007*

**Pipe Details:** SN4 (Class 200) HD 160mm Corrugated & Perforated

**Production Date:** May 2019

**Batch No's:** 05-2019-160HD

**Material:** HDPE

Terry Hammerton  
**QA Coordinator**

**04/07/2019**