



# Certificate of Compliance

This Certifies that

**100mm SN8 (Class 400) Flexi pipe**

Manufactured by Cromford Pipe  
Conforms to:

Specifications	AS 2439	Test Method	Requirement	Result	
Freedom from defects	2.3	Visual inspection	Clause 2.3.1	√	Pass
Diameter	2.4.1	Appendix B	Within OD range of 99.0mm & 102.0mm	√	Pass
Length	2.4.2	Measurement	Clause 2.4.2	√	Pass
Physical Properties	3.1	Appendix B	Slot range 3 > <10 with minimum 1500mm <sup>2</sup> /LM	√	Pass
Stiffness Properties	5.7	AS/NZS 1462.22	>8000 @ 5% Deflection >6400 @ 10% Deflection	√	Pass

## Using test methods specified in:

*AS 2439.1 Perforated Drainage Pipe and Associated Fittings, Part 1 2007*

**Pipe Details:** SN8 (Class 400) HD 100mm Corrugated & Perforated

**Production Date:** July-2019

**Batch No's:** 07-2019-100HD

**Material:** HDPE

Terry Hammerton  
**QA Coordinator**

10/07/2019