



Certificate of Compliance

This Certifies that

80mm SN8 (Class 400) Flexi pipe

Manufactured by Cromford Pipe
Conforms to:

Specifications	AS 2439	Test Method	Requirement	Result	
Freedom from defects	2.3	Visual inspection	Clause 2.3.1	√	Pass
Diameter	2.4.1	Appendix B	Within OD range of 79.0mm & 82.0mm	√	Pass
Length	2.4.2	Measurement	Clause 2.4.2	√	Pass
Physical Properties	3.1	Appendix B	Slot range 3 > <10 with minimum 1500mm ² /LM	√	Pass
Stiffness Properties	5.7	AS/NZS 1462.22	>8000 @ 5% Deflection >6400 @ 10% Deflection	√	Pass

Using test methods specified in:

AS 2439.1 Perforated Drainage Pipe and Associated Fittings, Part 1 2007

Pipe Details: SN8 (Class 400) HD 80mm Corrugated & Perforated

Production Date: July-2019

Batch No's: 07-2019-80HD

Material: HDPE

Terry Hammerton
QA Coordinator

10/07/2019